

Bureau of Health Care Quality and Compliance

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: NVS3543AGZ	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 02/23/2010
NAME OF PROVIDER OR SUPPLIER COTTAGES OF GREEN VALLEY		STREET ADDRESS, CITY, STATE, ZIP CODE 2620 E ROBINDALE ROAD HENDERSON, NV 89074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
Y 000	Initial Comments The findings and conclusions of any investigation by the Health Division shall not be construed as prohibiting any criminal or civil investigations, actions or other claims for relief that may be available to any party under applicable federal, state, or local laws. This Statement of Deficiencies was generated as a result of a required grading re-survey conducted in your facility on 2/23/10. This State Licensure survey was conducted by the authority of NRS 449.150, Powers of the Health Division. The facility received a grade of A. The following additional deficiencies were found:	Y 000		
Y 356 SS=F	449.222(6) Bathrooms and Toilet Facilities NAC 449.222 6. Bathroom doors that are equipped with locks must open with a single motion from the inside without the use of a key. If a key is required to open a lock from outside the bathroom, the key must be readily available at all times. This Regulation is not met as evidenced by: Based on observation on 2/23/10, the facility did not ensure the locks on 6 of 6 bathroom doors could be opened with a single motion (Bathroom #1, #2, #3, #4, #5 and #6). Severity: 2 Scope: 3	Y 356		

If deficiencies are cited, an approved plan of correction must be returned within 10 days after receipt of this statement of deficiencies.

TITLE

(X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE