

**STATE OF NEVADA HEALTH DIVISION  
PUBLIC HEALTH AND CLINICAL SERVICES EHS  
RESIDENTIAL SEPTIC SYSTEM APPLICATION**

FOR OFFICE USE ONLY

PERMIT NO. \_\_\_\_\_

DATE ISSUED \_\_\_\_\_

EXPIRATION DATE \_\_\_\_\_

---

**GENERAL INSTRUCTIONS:** Please fill out the application in full. Do not leave spaces blank or we will assume you have omitted information and your application may be delayed. Two (2) percolation tests are required for each system. The permit cannot be issued without good, sound, complete percolation data. Fees are due when the permit application is submitted and before the issuance of the construction permit. Each system is \$498.00. Please make your check payable to NEVADA STATE HEALTH DIVISION.

---

**GENERAL INFORMATION:**

APPLICANT NAME \_\_\_\_\_ TELEPHONE \_\_\_\_\_

MAILING ADDRESS \_\_\_\_\_ CITY \_\_\_\_\_

CONSTRUCTION LOCATION \_\_\_\_\_ ASSESSOR PARCEL NO. \_\_\_\_\_

GROSS ACREAGE OF LOT SYSTEM TO BE LOCATED ON \_\_\_\_\_

NUMBER OF BEDROOMS \_\_\_\_\_ NUMBER OF PEOPLE IN RESIDENCE \_\_\_\_\_

---

**WATER SOURCE:** (CHECK ONE) PRIVATE WELL \_\_\_\_\_ SHARED WELL \_\_\_\_\_ PUBLIC WATER SYSTEM \_\_\_\_\_

WELL DIAMETER: \_\_\_\_\_ WELL DEPTH \_\_\_\_\_ CASING DEPTH \_\_\_\_\_

NAME OF WELL DRILLER \_\_\_\_\_

NAME OF WATER SYSTEM IF PUBLIC \_\_\_\_\_

NOTE: YOUR WELL MUST BE DRILLED PRIOR TO YOUR FINAL INSPECTION TO VERIFY DISTANCES.

---

**SEPTIC TANK:** SIZE \_\_\_\_\_ PURCHASED WHERE? \_\_\_\_\_ MANUFACTURER \_\_\_\_\_

DISTANCE FROM WELL TO TANK \_\_\_\_\_ DISTANCE TO NEIGHBORING WELLS \_\_\_\_\_

DISTANCE FROM FOUNDATION OF DWELLING TO TANK \_\_\_\_\_

NOTE: IT IS RECOMMENDED THAT YOU FILL THE TANK WITH WATER TO VERIFY THAT THE CONNECTIONS ARE WATERTIGHT AND TO INCREASE THE TANK'S STRENGTH DURING BACKFILLING

---

**LEACH FIELD:** DISTANCE FROM YOUR WELL TO LEACH FIELD \_\_\_\_\_

DISTANCE FROM NEIGHBORING WELLS TO YOUR LEACH FIELD \_\_\_\_\_

NUMBER OF LINES \_\_\_\_\_ LENGTH OF EACH LINE \_\_\_\_\_ NUMBER OF

CHAMBERS \_\_\_\_\_ MANUFACTURER IF CHAMBERS ARE BEING USED AND MODEL NUMBER OF

CHOSEN CHAMBER SYSTEM \_\_\_\_\_

DISTANCE BETWEEN LINES (IF APPLICABLE) \_\_\_\_\_ TRENCH WIDTH \_\_\_\_\_

**LEACH FIELD CONTINUED:** DEPTH OF TRENCH BEFORE ROCK IS PLACED \_\_\_\_\_ LEACH ROCK SOURCE \_\_\_\_\_

AMOUNT OF ROCK UNDER LEACH PIPE \_\_\_\_\_ OVER LEACH PIPE \_\_\_\_\_ CAP ON END OF PIPE? \_\_\_\_\_

**COVER MATERIAL:** UNTREATED BUILDING PAPER \_\_\_\_\_ STRAW \_\_\_\_\_ GEOTEXTILE \_\_\_\_\_

NO TAR PAPER PLEASE!

---

**INSTALLER INFORMATION:**

INSTALLER NAME \_\_\_\_\_ TELEPHONE \_\_\_\_\_

MAILING ADDRESS \_\_\_\_\_ CITY \_\_\_\_\_

---

**COMMENTS OR OTHER PERTINENT INFORMATION:**

---

**APPLICANT'S SIGNATURE:** \_\_\_\_\_ **DATE:** \_\_\_\_\_

---

**PLOT PLAN INFORMATION:**

**THE FOLLOWING INFORMATION SHALL BE SHOWN ON THE PLOT PLAN (NAC 444.784.3)**

- (a) The title and date of the plan and the signature of the owner or his representative.
- (b) A map of the area in which the individual sewage disposal system will be located that shows the location of the roads and streets.
- (c) The location and distance to well and sewage systems on surrounding lots. If the lots are vacant, the plot plan must so indicate.
- (d) The direction of north clearly indicated.
- (e) The distance within 500 feet to any watercourse indicated, including, without limitation, any pond, lagoon or stream. If there are no watercourses, the plot plan must so indicate.
- (f) The location of each percolation test hole and boring test hole.
- (g) The location and depth of each proposed and/or actual well located within 200' of the proposed individual sewage disposal system. A well log must be included for any well located less than 150' from the absorption field.
- (h) Each component of the individual sewage disposal system, which must be properly marked and located at specified distances.
- (i) The distance to city sewers. If there are none, the plot plan must so indicate.
- (j) The distance of each well and soil absorption system to the property line.
- (k) The scale to which the plan is drawn, such as 1 inch = 30 feet, 40 feet, 50 feet, 60 feet, etc.
- (l) The number of bedrooms in the single-family dwelling.
- (m) The capacity of the septic tank.
- (n) The maximum slope across the absorption system area.
- (o) The dimensions of the lot.
- (p) The depth, length, width and spacing of any absorption trenches.
- (q) The location of the water supply lines, building sewer lines and other underground utilities.
- (r) The location of the structures, paved areas, driveways, trees and patios.
- (s) The location of the source of water to be used by the individual sewage disposal system, including, without limitation, a well or other source approved by the administrative authority.
- (t) The location of the reserve absorption area, which must be of a size not less than the size of the primary absorption area.

**STATE OF NEVADA HEALTH DIVISION  
PUBLIC HEALTH AND CLINICAL SERVICES EHS  
RESIDENTIAL SEPTIC SYSTEM APPLICATION  
PLOT PLAN SHOWING ALL ITEMS INCLUDED IN NAC 444.784.3 - SEE PAGE 2 - INDICATE  
SCALE IF DRAWN TO SCALE                   SCALE = \_\_\_\_\_**

## RESIDENTIAL SEPTIC SYSTEM APPLICATION PERCOLATION TEST DATA

<b>Hole #</b> <u>  1  </u>	<b>Percolation Rate:</b> _____ <b>Minutes/Inch</b>			
Depth From Native Ground Surface That Percolation Test Was Conducted:				
Presoak Start Time:			Presoak End Time:	
Number of Hours That Soil Was Presoaked:				
TIME	DEPTH TO WATER	INTERVAL	DROP OF WATER IN INCHES	MIN/INCH

<b>Hole #</b> <u>  2  </u>	<b>Percolation Rate:</b> _____ <b>Minutes/Inch</b>			
Depth From Native Ground Surface That Percolation Test Was Conducted:				
Presoak Start Time:			Presoak End Time:	
Number of Hours That Soil Was Presoaked:				
TIME	DEPTH TO WATER	INTERVAL	DROP OF WATER IN INCHES	MIN/INCH



**STATE OF NEVADA HEALTH DIVISION  
PUBLIC HEALTH AND CLINICAL SERVICES EHS  
RESIDENTIAL SEPTIC SYSTEM APPLICATION SET BACK DISTANCES**

Minimum horizontal distance, in clear, required from:	Building sewer drain	Septic tank	Disposal field (shallow)
Building or structure	—	8'	8'
Property lines	10'	10'	10'
Water supply wells (sealed to 50 feet)	50'	100'	100'
Water supply wells (not sealed to 50 feet)	50'	100'	150' *
Public water supply wells	50'	150'	150' *
Streams or watercourses	50'	100'	100'
Drainage channels	25'	25'	25'
Large trees or shrubs	—	10'	10'
Disposal fields	—	5'	—
Community water main line	10'	10'	25'
Individual water service line	10'	10'	25'
Dry wells	—	6'	20'

\* The required distance between a well and the components of an individual sewage disposal system may be increased by the administrative authority depending on the depth to the water table, soil profile and site characteristics.

**NAC 444.8306 Capacity of septic tank serving single-family dwelling. ([NRS 439.200](#), [444.650](#))**

1. The minimum capacity for a septic tank that serves a single-family dwelling is based on the number of bedrooms in the dwelling, and is determined as follows:

Number of Bedrooms	Minimum Liquid Capacity of Tank (in Gallons)
3 or less	1,000
4	1,200
5 or 6	1,500